



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

SIW Impact Windows, LLC
975 S. Congress Avenue, # 102
Delray Beach, FL 33445

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/ or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code. This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series "250 XXL StormSafe" Aluminum Horizontal Sliding Window - L.M.I.

APPROVAL DOCUMENT: Drawing No. W14-42, titled "S-250 XXL StormSafe Alum. Horiz. Rolling Wdw. (L.M.I.)", sheets 1 through 06 of 06, dated 12/05/14, with revision A dated 06/01/15, prepared by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E., bearing the Miami-Dade County Product Control Section Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/ or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 12-0221.07 and consists of this page 1 and evidence pages E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by **Manuel Perez, P.E.**



MP
7/6/15

NOA No. 15-0102.02
Expiration Date: August 01, 2017
Approval Date: June 18, 2015
Page 1

SIW Impact Windows, LLC.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS


1. Manufacturer's die drawings and sections.
2. Drawing No. **W14-42**, titled "S-250 XXL StormSafe Alum. Horiz. Rolling Wdw. (L.M.I.)", sheets 1 through 6 of 6, dated 12/05/14, with revision A dated 06/01/15, prepared by Al-Farooq Corporation, signed, sealed by Javad Ahmad, P.E.

B. TESTS

1. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
3) Water Resistance Test, per FBC, TAS 202-94
4) Forced Entry Test, per FBC 2411.3.2.1, and TAS 202-94
5) Large Missile Impact Test per FBC, TAS 201-94
6) Cyclic Wind Pressure Loading per FBC, TAS 203-94
along with marked-up drawings and installation diagram of a series 200 aluminum horizontal rolling window, prepared by Blackwater Testing, Inc., Test Reports No.'s **BT-SIW-14-017C**, dated 09/22/14 and **BT-SIW-14-017D**, dated 09/25/14, both signed and sealed by Yamil Gerardo Kuri, P.E.
2. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
3) Water Resistance Test, per FBC, TAS 202-94
4) Forced Entry Test, per FBC 2411.3.2.1, and TAS 202-94
along with marked-up drawings and installation diagram of a series 200 aluminum horizontal rolling window, prepared by Hurricane Engineering & Testing, Inc., Test Reports No. **HETI-06-4085**, **HETI-06-4086**, **HETI-06-4087**, **HETI-06-4094** and **HETI-06-4179**, dated 02/26/07 and 07/25/07, all signed and sealed by Rafael E. Droz-Seda, P.E. (*Submitted under NOA's No. 07-0511.10 and 07-0813.05*)
3. Test reports on: 1) Large Missile Impact Test per FBC, TAS 201-94
2) Cyclic Wind Pressure Loading per FBC, TAS 203-94
along with marked-up drawings and installation diagram of a series 200 aluminum horizontal rolling window, prepared by Hurricane Engineering & Testing, Inc., Test Reports No. **HETI-06-4089**, **HETI-06-4090**, **HETI-06-4092**, **HETI-06-4095**, **HETI-07-4126** and **HETI-07-4282**, dated 02/26/07 and 07/25/07, all signed and sealed by Rafael E. Droz-Seda, P.E.
(*Submitted under NOA's No. 07-0511.10 and 07-0813.05*)

C. CALCULATIONS

1. Anchor verification calculations and structural analysis, complying with **FBC 5th Edition (2014)**, prepared by Al-Farooq Corporation, dated 12/29/14 with revision dated 06/01/15, signed and sealed by Javad Ahmad, P.E.
2. Glazing complies with **ASTM E1300-09**


Manuel Perez, P.E.
Product Control Examiner
NOA No. 15-0102.02
Expiration Date: August 01, 2017
Approval Date: June 18, 2015

SIW Impact Windows, LLC.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS

1. Notice of Acceptance No. **13-0129.27** issued to **E.I. DuPont DeNemours & Co., Inc.** for their "**DuPont Butacite® PVB Interlayer**" dated 04/11/13, expiring on 12/11/16.
2. Notice of Acceptance No. **14-0423.17** issued to **Eastman Chemical Company (MA)** for their "**Saflex Clear and Color Glass Interlayers**" dated 06/19/14, expiring on 05/21/16.
3. TREMCO Part No. **Vulkem 116 LV White Polyurethane Sealant** complying with ASTM C1183- 0.135-0.169fl.oz./min., ASTM C661- ±40 A, ASTM C1246- PASS-6 HRS., ASTM C679- 30 HRS., ASTM C510- NO STAIN, ASTM C794- ALUMINUM 18-22 PLI, CONCRETE 20-25 PLI AND BRICK 19-23 PLI, ASTM C793- PASS, ASTM C719- ±25% AND ASTM D412- 150-200 PSI.

F. STATEMENTS

1. Statement letter of conformance, complying with **FBC 5th Edition (2014)**, and of no financial interest, dated 12/29/14, issued by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E.
2. Laboratory compliance letter for Test Reports No. **BT-SIW-14-017E**, dated 09/25/14 and **BT-SIW-14-017F**, dated 09/22/14, issued by Blackwater Testing, Inc., both signed and sealed by Yamil Gerardo Kuri, P.E.
3. Proposal issued by the Product Control Section, dated 09/19/14, signed by Jaime D. Gascon, P.E.
4. Statement letter of conformance, complying with **FBC-2010**, issued by Al-Farooq Corporation, dated 12/30/11, signed and sealed by Javad Ahmad, P. E.
(Submitted under previous NOA No. 12-0221.07)
5. Laboratory compliance letter for Test Reports No. **HETI-06-4085, HETI-06-4086, HETI-06-4087, HETI-06-4089, HETI-06-4090, HETI-06-4092, HETI-06-4094, HETI-06-4095, HETI-06-4179, HETI-07-4126 and HETI-07-4282**, issued by Hurricane Engineering & Testing, Inc., dated 02/26/07 and 07/25/07, all signed and sealed by Rafael E. Droz-Seda, P.E.
(Submitted under NOA's No. 07-0511.10 and 07-0813.05)

G. OTHERS



1. Notice of Acceptance No. **12-0221.07**, issued to SIW Impact Windows, LLC for their Series "200 StormSafe" Aluminum Horizontal Sliding Window – L.M.I.", approved on 04/26/12 and expiring on 08/01/17.


Manuel Perez, P.E.
Product Control Examiner

NOA No. 15-0102.02

Expiration Date: August 01, 2017

Approval Date: June 18, 2015



TYPICAL ELEVATIONS

THESE WINDOWS ARE RATED FOR LARGE & SMALL MISSILE IMPACT. SHUTTERS ARE NOT REQUIRED.

SERIES 250 XXL STORMSAFE ALUMINUM HORIZONTAL SLIDING WINDOW

APPROVAL APPLIES TO SINGLE UNITS OR SIDE BY SIDE COMBINATIONS OF H.S./H.S. OR HORIZONTAL SLIDING WITH OTHER WINDOW TYPES IN MODULES OF TWO OR MORE WINDOWS USING MIAMI-DADE COUNTY APPROVED MULLIONS IN BETWEEN. LOWER DESIGN PRESSURE FROM WINDOWS OR MULLION APPROVAL WILL APPLY TO ENTIRE SYSTEM.

THIS PRODUCT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE FLORIDA BUILDING CODE INCLUDING HIGH VELOCITY HURRICANE ZONE (HVHZ).

WOOD BUCKS BY OTHERS, MUST BE ANCHORED PROPERLY TO TRANSFER LOADS TO THE STRUCTURE.

ANCHORS SHALL BE AS LISTED, SPACED AS SHOWN ON DETAILS, ANCHORS EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.

ANCHORING OR LOADING CONDITIONS NOT SHOWN IN THESE DETAILS ARE NOT PART OF THIS APPROVAL.

A LOAD DURATION INCREASE IS USED IN DESIGN OF ANCHORS INTO WOOD ONLY.

ALL SHIMS TO BE HIGH IMPACT, NON-METALLIC AND NON-COMPRESSIBLE.

MATERIALS INCLUDING BUT NOT LIMITED TO STEEL/METAL SCREWS, THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF THE FLORIDA BUILDING CODE.

MAXIMUM DESIGN LOAD RATING = + 60.0 PSF
(FOR SIZES SHOWN ABOVE OR SMALLER) - 60.0 PSF

NOTE:
GLASS CAPACITIES ON THIS SHEET ARE
BASED ON ASTM E1300-09 (3 SEC. GUSTS)
AND FLORIDA BUILDING COMMISSION
DECLARATORY STATEMENT DCA05-DEC-219

Engr: JAVAD AHMAD
CIVIL
FLA. PE # 70592
C.A.N. 3538




JUN 10 2015

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 15-0102.02
Expiration Date 08/01/2017
By *Mamun*
Miami Dade Product Control

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANL W14-42SIW

S-250 XXL STORMSAFE ALUM. HORIZ. ROLLING WDW. (L.M.I.)
SIW IMPACT WINDOWS, LLC.
975 S. CONGRESS AVE. #102
DELRAY BEACH, FL. 33445
TEL. (561) 274-9392 FAX. (561) 274-9262

revisions:	no.	date	by	description
	A	06.01.15		NO CHANGE THIS SHEET
date:	12-05-14			
scale:	1/2" = 1'-0"			
dr. by:	HAMID			
chk. by:				
drawing no.	W14-42			
sheet	1 of 6			



PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 15-0102.02
Expiration Date 08/01/2017
By Manuel Perez
Milam/Dade Product Control

MAXIMUM DESIGN LOAD RATING = + 60.0 PSF
(FOR SIZES SHOWN ABOVE OR SMALLER) - 60.0 PSF

NOTE:
GLASS CAPACITIES ON THIS SHEET ARE
BASED ON ASTM E1300-09 (3 SEC. GUSTS)
AND FLORIDA BUILDING COMMISSION
DECLARATORY STATEMENT DCA05-DEC-219

Engr: JAVAD AHMAD
CIVIL
FLA. PE # 70592
C.A.N. 3538

APR 10 2015

AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978

5-250 XXL STORMSAFE ALUM HORIZ. ROLLING WDW. (L.M.I.)

SIW IMPACT WINDOWS, LLC.
975 S. CONGRESS AVE. #102
DELRAY BEACH, FL 33445
TEL. (561) 274-9392 FAX. (561) 274-9262





[illegible]

date: 12-05-14
scale: $1/2" = 1'$
dr. by: HAMID
chk. by:

drawing no.
W14-42

sheet 2 of 6

sheet 2 of 6



WOOD BUCKS AND METAL STRUCTURE NOT BY S.I.W. MUST SUSTAIN LOADS IMPOSED BY GLAZING SYSTEM AND TRANSFER THEM TO THE BUILDING STRUCTURE.

SEALANTS:

ALL JOINTS AND FRAME CONNECTIONS SEALED WITH SILICONE OR ACRYLIC SEALANT.

WEEPHOLES:

- W1 = 1" X 1/4" WEEPHOLES IN PAIRS
 (2) ON VENT AREA AT 2" FROM ENDS AND 26" O.C.
 (4) UNDER FIX. LITE AT 18" O.C.
- W2 = 1-3/4" X 1/4" WEEPHOLES WITH NYLON BAFFLE
 (2) ON VENT AREA AT 15" FROM ENDS AND 24" O.C.
 (3) UNDER FIX. LITE AT 16" O.C.

TYPICAL ANCHORS:

SEE ELEV. FOR SPACING
 1/4" DIA. ULTRACON BY 'ELCO' (Fu=177 KSI, Fy=155 KSI)

INTO 2BY WOOD BUCKS OR WOOD STRUCTURES
 1-1/2" MIN. PENETRATION INTO WOOD

THRU 1BY BUCKS INTO CONC. OR MASONRY
 1-1/4" MIN. EMBED INTO CONC. OR MASONRY

DIRECTLY INTO CONC. OR MASONRY
 1-1/4" MIN. EMBED INTO CONC. OR MASONRY

#14 SMS OR SELF DRILLING SCREWS (GRADE 2 CRS)
 INTO METAL STRUCTURES

STEEL : 12 GA. MIN. (Fy = 36 KSI MIN.)
 ALUMINUM : 1/8" THK. MIN. (6063-T5 MIN.)
 (STEEL IN CONTACT WITH ALUMINUM TO BE PLATED OR PAINTED)


#12 SMS OR SELF DRILLING SCREWS (GRADE 2 CRS)

INTO MIAMI-DADE COUNTY APPROVED MULLIONS (MIN. THK. = 1/8")
 (NO SHIM SPACE)

TYPICAL EDGE DISTANCE

INTO CONCRETE AND MASONRY = 1-3/4" MIN.
 INTO WOOD STRUCTURE = 1" MIN.
 INTO METAL STRUCTURE = 1/2" MIN.

WOOD AT HEAD, SILL OR JAMBS SG = 0.55 MIN.
 CONCRETE AT HEAD, SILL OR JAMBS f'c = 3000 PSI MIN.
 C-90 HOLLOW/FILLED BLOCK AT JAMBS f'm = 2000 PSI MIN.




PRODUCT REVISED
 as complying with the Florida
 Building Code
 Acceptance No. 15-0102.02
 Expiration Date 08/01/2017
 By *Manuel Cruz*
 Miami Dade Product Control

Engr: JAVAD AHMAD
 CIVIL
 FLA. PE # 70592
 C.A.N. 3538
 JUN 10 2015

AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 1235 S.W. 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL/W14-42SIW

S-250 XXL STORMSAFE ALUM. HORIZ. ROLLING WDW. (L.M.I.)
SIW IMPACT WINDOWS, LLC.
 975 S. CONGRESS AVE. #102
 DELRAY BEACH, FL. 33445
 TEL. (561) 274-9392 FAX. (561) 274-9262

revisions:	no.	date	by	description
	A	06.01.15		REV. PER PER COMMENTS
date:	12-05-14			
scale:	1/2" = 1"			
dr. by:	HAMID			
chk. by:				
drawing no.	W14-42			
sheet	3 of 6			




EXTERIOR

WINDOW WIDTH

XO LAYOUT
OX OPPOSITE


MIAMI-DADE COUNTY
APPR'D CLIPPED MULLION
SEE SEPARATE NOA

TYPICAL ANCHORS
SEE ELEV.
FOR SPACING



WINDOW WIDTH

WINDOW WIDTH



EXTERIOR

WINDOW WIDTH

XOX LAYOUT

1/4\"/>

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 15-0102.02
Expiration Date 08/01/2017

By *Manuel Perez*
Miami Dade Product Control

Engr: JAVAD AHMAD
CIVIL
FLA. PE # 70592
C.A.N. 3538

JUN 10 2015

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL (305) 264-8100 FAX (305) 262-6978
COMP-ANL W14-42SIW

S-250 XXL STORMSAFE ALUM HORIZ. ROLLING WDW. (L.M.I.)
SIW IMPACT WINDOWS, LLC.
975 S. CONGRESS AVE. #102
DELRAY BEACH, FL. 33445
TEL (561) 274-9392 FAX (561) 274-9262


revisions:		
no	date	description
A	06.01.15	REV. PER PER COMMENTS

date: 12-05-14	scale: 1/2" = 1"	dr. by: HAMID	chk. by:
----------------	------------------	---------------	----------


drawing no.

W14-42


sheet 4 of 6




① FRAME HEAD




② FRAME SILL




③ SILL TRACK




④ FRAME JAMB (VENT SIDE)




⑥ VENT TOP/BOTTOM RAIL




⑧ JAMB STILE




⑦ MEETING STILE



⑤ FIXED MTG. STILE



④A FRAME JAMB (FIX. SIDE)




⑫ SPRING LATCH

ITEM	PART #	QUANTITY	DESCRIPTION	MATERIAL	MANF./SUPPLIER/REMARKS
1	SIW201	1	FRAME HEAD	6063-T6	-
2	SIW202	1	FRAME SILL	6063-T6	-
3	SIW213	1	SILL TRACK	6063-T6	-
4	SIW204	2	FRAME JAMB (VENT SIDE)	6063-T5	-
4A	SIW131	2	FRAME JAMB (FIX SIDE)	6063-T5	-
5	SIW206	1/ VENT	FIXED MTG. RAIL	6063-T5	-
6	SIW107	2/ VENT	VENT TOP & BOTTOM RAIL	6063-T5	-
7	SIW105	1/ VENT	VENT INTERLOCK	6063-T5	-
8	SIW106	1/ VENT	VENT JAMB STILE	6063-T6	-
9	SIW108	AS REQD.	GLAZING BEAD (7/16" GLASS)	6063-T5	-
9.1	SIW127	AS REQD.	ALT. GLAZING BEAD (7/16" GLASS)	6063-T5	-
11	2K356B22	2/ VENT	SWEEP LATCH, AT 15-1/2" FROM EACH END	-	MASSOUD & BROS. CO.
12	SIW109	2/ VENT	SPRING LATCH, AT 15-1/2" FROM EACH END	6063-T6	-
13	-	AS REQD.	FRAME & VENT ASSY SCREWS	-	#10 X 1-1/2" PH SMS
14A	-	2/ VENT	FIXED RAIL SCREW AT TOP	-	#12 X 1-1/2" PH SMS
14B	-	2/ VENT	FIXED RAIL SCREW AT BOTTOM	-	#12 X 4" PH SMS
15	SIW207	4/ VENT	ROLLER HOUSING & GUIDE	DELTRIN	-
16	SIW208	2/ VENT	ROLLER	-	BRASS OR ST. STEEL
17	SIW209	2/ VENT	ROLLER PIN	ST. STEEL	-
18	-	5/ WDW.	BAFFLE	NYLON	-
19	-	2/ LITE	SETTING BLOCK, DUROMETER 85±5 SHORE A	EPDM	-
20	W23201NG	AS REQD.	TOP & BOTTOM RAIL W'STRIPPING	-	ULTRAFAB OE EQUIV.
21	9302BL	AS REQD.	FRAME JAMB W'STRIPPING	POLYPROPYLENE	CENTRAL PLASTICS
22	-	OPTIONAL	SCREEN	-	5/16" BOX
23	U4513	AS REQD.	BULB W'STRIPPING	-	SCHLEGEL
24	5531	AS REQD.	EXTERIOR GLAZING SPACER, DUROMETER 70±5 SHORE A	SANTOPRENE	CENTRAL PLASTICS
25	5530	AS REQD.	INTERIOR GLAZING SPACER, DUROMETER 70±5 SHORE A	SANTOPRENE	CENTRAL PLASTICS


⑭ EXTERIOR GLAZING SPACER
SCALE 1:1

⑮ INTERIOR GLAZING SPACER
SCALE 1:1



⑨

GLAZING BEADS (7/16" GLASS)



⑨.1







PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 15-0102.02
Expiration Date 08/01/2017
By *[Signature]*
Miami Dade Product Control

Engr: JAVAD AHMAD
CIVIL
FLA. PE # 70592
C.A.N. 3538
JUN 10 2015

afC
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL (305) 264-8100 FAX (305) 262-6978
COMP - ANL W14-42SIW

S-250 XXL STORMSAFE ALUM. HORIZ. ROLLING WDW. (L.M.I.)
SIW IMPACT WINDOWS, LLC.
975 S. CONGRESS AVE. #102
DELRAY BEACH, FL. 33445
TEL (561) 274-9392 FAX (561) 274-9262

revisions:
no. date by description
A 06.01.15 NO CHANGE THIS SHEET
date: 12-05-14
scale: 1/2" = 1"
dr. by: HAMID
chk. by:
drawing no.
W14-42
sheet 5 of 6



PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 15-0102.02
Expiration Date 08/01/2017 FRAME
By Manuel Perez AT
Miami Dade Product Control

Engr: JAVAD AHMAD
CIVIL
FLA. PE # 70592
C.A.N. 3538

JUN 10 2015

AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL (305) 264-8100 FAX (305) 262-6978

SIW IMPACT WINDOWS, LLC.
975 S. CONGRESS AVE. #102
DELRAY BEACH, FL 33445
TEL. (561) 274-8392 FAX. (561) 274-9262

date: 12-05-14		revisions:	
scale: 1/2" = 1"		no	by description
dr. by: HAMID		A	06.01.15 NO CHANGE THIS SHEET
chk. by:			

drawing no.
W14-42

sheet 6 of 6